

Report on the Effectiveness of CosaTron Air Purification Systems in Reducing Outside Air for:

GFK Elementary School

Grand Forks, North Dakota

Contaminant Mass Balance Methodology

The Contaminant Mass Balance (CMB) calculation provides a scientific indication of the effect that CosaTron air purification systems will have on the contaminant within a controlled space. The CosaTron system accelerates the natural coagulation of particulate based on the space-charge in the room and in so doing, increases the effectiveness of the filter. In every case the amount of outside, or makeup, air can be reduced by installing CosaTron.

The calculation takes in to consideration the number of occupants, the volume, the type of activity and the filter efficiency. Values can then be calculated for 35% Make Up Air (MUA) scenario as ratified by the ASHRAE standards. We can now recalculate the amount the MUA can be further reduced by employing CosaTron air purification. In most cases the amount of MUA can be reduced by half and maintain the same level of contaminant in the space as at the 35% MUA level.

Contaminant Mass Balance Formula

$n := 194$ Number Of Occupants $g_p := 0.93$ Contaminant Generation Rate Per Person (CFM)

$G := \frac{g_p n}{60}$ Total Contaminant Generation Rate (CFM) $G = 3.007$

Table 3, Chapter 11 1991 ASHRAE Handbook Carbon Dioxide Production	Scheduling Effort Synchronous Work Or Sports Moderate Exercise	5.70 3.80 2.50	Mild Exercise Or Light Work Standing Or Desk Work Sedentary Or All Ease Red ring Or All Rest	1.55 0.33 0.82 0.47
--	--	----------------------	---	------------------------------

$t := 0, 10, 240$ Time (Min) Start, Step, Stop

$q_3 := 20475$ Supply Air (CFM)

$q_0 := 1100$ Make Up Air Flow (CFM)

$q_2 := 0$ Infiltration Flow (CFM)

$q_1 := q_3 - q_0$ Recirculation Flow (CFM)

$q_1 = 1.938 \times 10^6$ (CFM)

$C_{i0} := 325 \cdot 10^{-6}$ Initial Inside Air Concentration (ppm)

$C_o := 325 \cdot 10^{-6}$ Outside Air Concentration (ppm)

$H_{ce} := 5$ Ceiling Height (Ft)

$A_{ce} := 18453$ Density Per 1000 Sq Ft

$V := H \cdot A$ $da := \frac{n}{A} \cdot 1000$

$V = 1.661 \times 10^5$ $da = 10.513$

Air Delivered Per Sq Ft:

$q_4 := \frac{q_1 + q_0}{A}$ $q_4 = 1.11$

k is Proportionality Constant For Contaminant Of Interest

R = (Deposition) (Volume)

$E := D \cdot V$

$k := 0.85$ Ventilation Effectiveness

$Fm := 0$ Filter Efficiency For Make Up

$Fr := 0$ Filter Efficiency For Recirculation

$Fmco := 0.15$ Filter Efficiency For Make Up With Coaslon

$Froco := 0.150$ Filter Efficiency For Recirculation With Coaslon

$D := .010$ Deposition Rate

$q_3 := \frac{q_0}{n}$ CFM Outside Air Per Person

$q_3 = 5.67$ CFM Per Person

$z := \frac{q_0}{q_3} \cdot 100$ $z = 5.372$ % Outside Air

$AC := q_3 \cdot \frac{60}{V}$ $AC = 7.397$ Air Changes Per Hour

Occupant Density: $\rho := \frac{n}{V}$ $\rho = 95.1 \text{ ft}^{-3}$ Person

R = Indoor Sink Removal Rate

R = (Deposition Rate) (Mass)

R = D · M

$R_r := D \cdot V \cdot C_i$

$R_r = 0.54$ CFM

Contaminant Mass Balance Equation 1

$$\frac{d}{dt}(C_i \cdot V) = k \cdot q_0 \cdot C_o (1 - Fm) + k \cdot q_1 \cdot C_i (1 - Fr) + k \cdot q_2 \cdot C_o - k \cdot (q_0 + q_1 + q_2) \cdot C_i + G - R$$

Equation 2 $d(C_i \cdot V) = 0$

$$0 = \frac{k \cdot [q_0 (1 - Fr) + q_2] \cdot C_o + G - R_r}{k \cdot (q_0 + q_1 \cdot Fm + q_2)} \left[1 - e^{-\left(\frac{k}{V}\right) \cdot (q_0 + q_1 \cdot Fm + q_2) \cdot t} \right] + C_{i0} e^{-\left(\frac{k}{V}\right) \cdot (q_0 + q_1 \cdot Fm + q_2) \cdot t}$$

Equation 3 When R is A First Order Function Of C_i The Solution Takes The Form:

$$C_i = \frac{[k \cdot (1 - FR) + q_2] \cdot C_o + G}{k \cdot (q_0 + q_1 \cdot F1 + q_2) + E} \left[1 - e^{-\left(\frac{k}{V}\right) \cdot (q_0 + q_1 \cdot Fm + q_2) \cdot t} \right] + C_{i0} e^{-\left(\frac{k}{V}\right) \cdot (q_0 + q_1 \cdot Fm + q_2) \cdot t}$$

Equation 4 Substituting E = DV and Equation 1 into Equation 2 Leads To:

$$\frac{C_i}{C_o} = \frac{\frac{n \cdot t}{V} + \frac{n}{n} \left(\frac{n \cdot t}{V} - 1 \right)}{e^{\frac{n \cdot t}{V}} - 1}$$

$n := -k \cdot q_1 \cdot Fr - k \cdot q_0 - k \cdot q_2 - D$ $n = -2.596 \times 10^3$ $n \cdot t := -k \cdot q_1 \cdot Froco - k \cdot q_0 - k \cdot q_2 - D \cdot t$ $n \cdot t = -5.066 \times 10^3$

$\beta := k \cdot q_2 \cdot C_o + k \cdot q_0 \cdot (1 - Fm) \cdot C_o + \beta = 3.311$ $\beta \cdot t := k \cdot q_2 \cdot C_o + k \cdot q_0 \cdot (1 - Fmco) \cdot C_o + \beta \cdot t = 3.265$

$C_{i1} := C_{i0} e^{\frac{n \cdot t}{V}}$ $C_{i2} := \frac{\beta \cdot t}{n} \left(e^{\frac{n \cdot t}{V}} - 1 \right)$ $Cot_1 := C_{i0} e^{\frac{n \cdot t}{V}}$ $Cot_2 := \frac{\beta \cdot t}{n} \left(e^{\frac{n \cdot t}{V}} - 1 \right)$

$C_{i1} = 1$ $C_{i2} = 1$ $Cot_1 = 1$ $Cot_2 = 1$

$C_i(t) := C_{i0} e^{\frac{n \cdot t}{V}} + \frac{\beta \cdot t}{n} \left(e^{\frac{n \cdot t}{V}} - 1 \right)$ $Cot(t) := C_{i0} e^{\frac{n \cdot t}{V}} + \frac{\beta \cdot t}{n \cdot t} \left(e^{\frac{n \cdot t}{V}} - 1 \right)$

Converting to ppm $M(t) := C_i(t) \cdot 10^6$ $Mot(t) := Cot(t) \cdot 10^6$

Contaminant Concentration Without Coaslon (ppm)

By Letting β Approach 0 Equation 4 Results in:

$$Miss := \left[\frac{k \cdot C_o [q_0 (1 - Fm) + q_2] + G}{k \cdot (q_0 + q_1 \cdot Fr + q_2) + E} \right] \cdot 10^6$$

Steady State Contaminant Concentration Without Coaslon

$Miss = 1.275 \times 10^3$

Contaminant Concentration With Coaslon (ppm)

$$Missot := \left[\frac{k \cdot C_o [q_0 (1 - Fmco) + q_2] + G}{k \cdot (q_0 + q_1 \cdot Froco + q_2) + E} \right] \cdot 10^6$$

Steady State Contaminant Concentration With Coaslon

$Missot = 644.54$

The Contaminant Mass Balance Calculation Formula

Results


The following are the results for the 6 Air Handling Units proposed at the GFK Elementary School.

AHU #	Use	Max Occ.	SQ Ft	Total CFM	ASHRAE STD 35% MUA	MUA With CosaTron	% MUA With CosaTron	MUA Reduction
AHU 1	Classroom/office	307	16,728	16,000	1.006X10 ³	2420	15.1	57%
AHU 2	Classroom	284	17,112	20,000	845.885	2510	12.5	64%
AHU 3	Cafeteria/reheat	245	5,411	8,300	1.556X10 ³	1570	18.9	46%
AHU 4	Gym	85	5,580	9,000	1.475X10 ³	1650	18.4	47%
AHU 5	Classroom	237	18,054	20,740	728.517	1940	10.1	71%
AHU 6	Classroom	194	18,453	20,475	643.728	1100	6.01	83%


Conclusion

The calculations indicate that the school can expect a 61% reduction in MUA and maintain acceptable levels of contaminant as defined by the ASHRAE standard by deploying CosaTron throughout the facility.


AHU 1: MUA Required to Match ASHRAE Standard: 15.1% or 57% MUA Reduction




AHU 2: MUA Required to Match ASHRAE Standard: 12.5% or 64% MUA Reduction




AHU 3: MUA Required to Match ASHRAE Standard: 18.9% or 46% MUA Reduction



AHU 4: MUA Required to Match ASHRAE Standard: 18.4% or 47% MUA Reduction



AHU 5: MUA Required to Match ASHRAE Standard: 10.1% or 71% MUA Reduction



AHU 6: MUA Required to Match ASHRAE Standard: 10.1% or 71% MUA Reduction

